

ADDENDUM

Page 1 of 1

This Addendum is a part of the Contract Documents and modifies the previously issued Bidding Documents.
****Acknowledge receipt of this Addendum by official's initials and date; failure to do so may result in rejection of the Bid**.**

Item 1: Addresses the application of primers and coating system as it relates to areas of exposed metal after corrosion remediation activity and areas where existing coatings are well adhered. The intent is to top coat only the areas in which the existing coatings are well adhered. Part 3.2.B.d alludes to this. In the areas where the existing coatings are well adhered application of the listed primer is not required. There will still be surface preparation requirements in these areas, but complete removal is not necessary. In areas where corrosion exists and/or the existing coatings have failed, complete removal is required. A coating manufactures alternate primer which does not require a commercial blast surface preparation and is compatible with the listed intermediate and top coat will be considered. In all cases areas which have corrosion and rusting must be removed to bare metal. The use of power tools such as grinders and needle guns per SSPC-SP3 is anticipated.

Initial/Date _____

Item 2: Addresses the total number of concrete saddles that are needing repair. There is a total of (3) three concrete saddles that require repair.

Initial/Date _____